



City known as the Town of  
**GREENFIELD, MASSACHUSETTS**

---

**DEPARTMENT of CENTRAL MAINTENANCE**

**GEORGE VANDELINDER**  
**Director**

**William F. Martin**  
**Mayor**

Town Hall • 14 Court Square • Greenfield, MA 01301  
Phone 413-772-1560 • Fax 413-772-1519  
GeorgeV@greenfield-ma.gov • www.greenfield-ma.gov

**RFQ TITLE: EXTERIOR PAINTING OF NORTH WING,  
GREENFIELD PUBLIC LIBRARY**

**RFQ #: 15-02**

**ADDEDUM # 3**

**Date of Issuance: September 17, 2014**

A second pre-visit was held on September 17 at 9AM. The following information was exchanged and further changes to the bid document are noted:

**ATTACHMENT E- SCOPE OF WORK**

**BUILDING BRICK**

- Removal of lead paint shall be confined to loose and peeling chips. Full removal is not necessary if adherence to brick is still acceptable in the Contractor's opinion.
- A low pressure wash shall be given to the complete brick exterior after loose paint removal. Contractor shall be responsible for taking the necessary precautions to contain all debris resulting from this procedure
- Contractor shall bring attention to the Town Representative about any wood found damaged or rotted.
- Painting requirements call for one coat of primer followed by one coat of paint..

**WOOD WINDOW AND TRIM**

- For clarification, removal of all glazing is not required. Sections that are still intact and show little sign of weathering can remain. Any loose sections that either are or show potential for wood exposure shall be removed and reglazed as needed.

**ATTACHMENT G- LEAD PAINT ABATEMENT REQUIREMENTS AND PROCEDURES**

Paragraph 1.2 DEBRIS DISPOSAL-

Due to a misinterpretation of regulations it has now been established that the lead contaminated material and debris generated must be handled as hazardous waste. Therefore this paragraph stands as written in the original bid document.

Paragraph 3.6 HAZARDOUS WASTE DISPOSAL

This paragraph has been reinstated to its original intent as written in the issued bid document.. See comments pertaining to Paragraph 1.2 DEBRIS DISPOSAL above

