



City of  
**GREENFIELD, MASSACHUSETTS**



**Greenfield Recreation Dept.**

20 Sanderson Street • Greenfield, MA 01301  
Phone 413-772-1553  
Christy.moore@greenfield-ma.gov

Virginia "Ginny" Desorgher  
Mayor

**IFB24-20 Construction of Bocce Courts, Greenfield, MA  
ADDENDUM #1**

DATE: March 25, 2024

THE ORIGINAL SPECIFICATIONS DATED March 13, 2024 FOR THE ABOVE-NOTED PROJECT ARE AMENDED AS NOTED IN THE ADDENDUM #1

THIS ADDENDUM IS ISSUED FOR THE PURPOSE OF AMENDING THE REQUIREMENTS OF THE CONTRACT DOCUMENTS AND IS HEREBY MADE PART OF THE CONTRACT DRAWINGS AND SPECIFICATIONS TO THE SAME EXTENT AS THOUGH IT WERE FULLY INCORPORATED THEREIN.

---

Please see below questions received with responses for consideration in preparing IFB responses:

1. Does the above project currently have an estimated mobilization date?
  - a. As soon as all paperwork is submitted to the city and a contract is signed
2. Are there any plans for trees, shrubs, or bushes?
  - a. At this time there are no definite plans for plantings as part of the Bid.
3. What is the make and model of the fountain and is it free draining?
  - a. Under Section 02-950, Part 2 Products, Sections 2.04 is Fountain Specs.
  - b. Purchased by owner: Drinking Fountain: Elkay Outdoor EZH20 Upper Bottle Filling Station Bi- Level Pedestal Model #LK4420BF1UEVG with LK4471LHBEVG Locking Hose Bib and Direct Bury Adaptor 9789C. Colt Plumbing: 1132 W Trindle Rd, Mechanicsburg, PA 17055. mail@coltplumbing.com Phone: 717.697.4618 <https://www.coltplumbing.com/colt/desktop.html>
  - c. These items will be directly purchased and installed by the Owner. Contractor will install direct bury bases in pads and connect new water service from existing service line to direct bury base per bid specs.
  - d. The fountain is free draining.

**Please acknowledge this Addendum #1 on the IFB Submittal Form  
END OF ADDENDUM**