

## ATTACHMENT A

### SUMMARY OF CONFIRMED ACM (TABLE 1.0)

TABLE 1.0

SUMMARY OF ASBESTOS MATERIALS TO BE ABATED  
 141 DAVIS STREET  
 GREENFIELD, MASSACHUSETTS

| NO. | FLOOR    | ROOM/LOCATION                          | MATERIAL                          | QUANTITY | UNIT | NOTES  |
|-----|----------|--|-----------------------------------|----------|------|--|
| 1   | 1st      | Bath Between Rooms 4 & 5               | Pipe and Fitting Insulation       | 2        | LF   |  |
| 2   | 1st      | Bath Between Rooms 4 & 5               | Pipe Fitting Insulation           | 4        | EA   |  |
| 3   | 1st      | Front Stair Bathroom                   | Pipe and Fitting Insulation       | 10       | LF   |  |
| 4   | 1st      | Front Stair Bathroom                   | Pipe Fitting Insulation           | 4        | EA   |  |
| 5   | 1st      | IT Room Between 1A & 2                 | Pipe and Fitting Insulation       | 15       | LF   |  |
| 6   | 1st      | IT Room Between 1A & 2                 | Pipe Fitting Insulation           | 4        | EA   |  |
| 7   | 1st      | Rear Stair Closet                      | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 8   | 1st      | Rear Stair Room 2                      | Black Sink Undercoat              | 4        | SF   |  |
| 9   | 1st      | Room 1                                 | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 10  | 1st      | Room 1                                 | Pipe Fitting Insulation           | 2        | EA   |  |
| 11  | 1st      | Room 1A                                | Pipe and Fitting Insulation       | 15       | LF   |  |
| 12  | 1st      | Room 2                                 | Pipe and Fitting Insulation       | 12       | LF   |  |
| 13  | 1st      | Room 2A                                | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 14  | 1st      | Room 2A                                | Pipe Fitting Insulation           | 2        | EA   |  |
| 15  | 1st      | Room 3                                 | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 16  | 1st      | Room 4                                 | Pipe and Fitting Insulation       | 12       | LF   |  |
| 17  | 1st      | Room 5                                 | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 18  | 1st      | Room 5                                 | Pipe and Fitting Insulation       | 15       | LF   |  |
| 19  | 1st      | Room 5                                 | Pipe Fitting Insulation           | 2        | EA   |  |
| 20  | 1st      | Room 6                                 | Pipe and Fitting Insulation       | 15       | LF   |  |
| 21  | 1st      | Room 6                                 | Pipe Fitting Insulation           | 5        | EA   |  |
| 22  | 2nd      | Front Stair Room 2                     | Black Sink Undercoat              | 4        | SF   |  |
| 23  | 2nd      | OSE Office                             | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 24  | 2nd      | Room 11                                | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 25  | 2nd      | Room 7                                 | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 26  | 2nd      | Room 8                                 | Black Sink Undercoat              | 4        | SF   |  |
| 27  | 2nd      | Room 8                                 | Heater Unit                       | 1        | EA   | Includes piping, paper and board behind unit             |
| 28  | 2nd      | Second Floor Hall                      | Floor Tile and Mastic             | 5        | SF   | Yellow/orange flooring near water fountain               |
| 29  | 2nd      | Second Floor Hall                      | Water Fountain                    | 1        | EA   | Includes piping, paper and board behind unit             |
| 30  | Attic    | Throughout Attic                       | White Electrical Insulation Paper | 75       | SF   |  |
| 31  | Basement | Basement Front Stairs                  | Pipe and Fitting Insulation       | 12       | LF   |  |
| 32  | Basement | Basement Main Hall                     | Pipe and Fitting Insulation       | 175      | LF   |  |
| 33  | Basement | Boiler Room                            | Boiler Unit                       | 1        | EA   | Includes all interior and exterior ACM                   |
| 34  | Basement | Boiler Room                            | Pipe and Fitting Insulation       | 45       | LF   |  |
| 35  | Basement | Boys Bathroom                          | Pipe and Fitting Insulation       | 50       | LF   |  |
| 36  | Basement | Boys Bathroom Crawlspace               | Pipe and Fitting Insulation       | 12       | LF   |  |
| 37  | Basement | Crawlspace Under Basement Front Stairs | Pipe and Fitting Insulation       | 25       | LF   |  |
| 38  | Basement | Rear Basement Storage                  | Pipe and Fitting Insulation       | 30       | LF   |  |
| 39  | Basement | Room 13                                | Pipe Gaskets                      | 3        | EA   | Assumed to be ACM  |
| 40  | Basement | Workshop                               | Fire door                         | 6        | EA   | Assumed to be ACM  |
| 41  | Basement | Workshop                               | Floor Tile and Mastic             | 1,000    | SF   |  |
| 42  | Basement | Workshop                               | Pipe and Fitting Insulation       | 25       | LF   |  |
| 43  | Basement | Workshop                               | Pipe Fitting Insulation           | 6        | EA   |  |
| 44  | Basement | Workshop Closet                        | 50 lb bag of raw asbestos         | 1        | EA   | 4 other bags of misc debris that shall be treated as ACM |
| 45  | Basement | Workshop Closet                        | Pipe and Fitting Insulation       | 25       | LF   |  |
| 46  | Basement | Workshop Closet                        | Pipe Fitting Insulation           | 7        | EA   |  |
| 47  | Exterior | All Sides of Building                  | Decorative Lower Stone Caulk      | 72       | EA   | Vertical joints on stone                                 |
| 48  | Exterior | All Sides of Building                  | Door Caulking                     | 4        | EA   | Includes old caulking on wood framework                  |

LF = Linear Foot  
 SF = Square Foot  
 EA = Each

TABLE 1.0

SUMMARY OF ASBESTOS MATERIALS TO BE ABATED  
 141 DAVIS STREET  
 GREENFIELD, MASSACHUSETTS

| NO. | FLOOR    | ROOM/LOCATION               | MATERIAL   | QUANTITY | UNIT | NOTES                       |
|-----|----------|-----------------------------|--|----------|------|-----------------------------|
| 49  | Exterior | All Sides of Building       | Window Caulking & Glazing Compound               | 116      | EA   | Includes boarded windows    |
| 50  | Exterior | All Sides of Building       | Vent Caulking                                    | 9        | EA   |                             |
| 51  | Exterior | All Sides of Building       | Window Caulking & Glazing Compound               | 8        | EA   | Transom Units               |
| 52  | Exterior | All Sides of Building       | Window Caulking & Glazing Compound               | 1        | EA   |                             |
| 53  | Exterior | Northwest Side of Building  | Roofing Material (Shingles, Tar Paper, Flashing) | 60       | SF   | Overhang roof               |
| 54  | Exterior | Southwest Side of Building  | Roofing Material (Shingles, Tar Paper, Flashing) | 120      | SF   | Overhang roof               |
| 55  | Exterior | Southeast Side of Building  | Roofing Material (Shingles, Tar Paper, Flashing) | 120      | SF   | Overhang roof               |
| 56  | Exterior | Main Roof - Sloped Sections | Roofing Material (Shingles, Tar Paper, Flashing) | 8,300    | SF   |                             |
| 57  | Exterior | Main Roof- Flat Section     | Roofing Material (Membrane, Built-Up Roof, etc.) | 200      | SF   |                             |
| 58  | Exterior | Roof Dormers                | Roofing Material (Shingles, Tar Paper, Flashing) | 1,200    | SF   | On roof and sides of Dormer |

LF = Linear Foot  
 SF = Square Foot  
 EA = Each