



**William F. Martin**  
Mayor

City of  
**GREENFIELD, MASSACHUSETTS**

---

**DEPARTMENT OF PUBLIC WORKS**

189 Wells Street, Greenfield, MA 01301  
Phone 413-772-1528 • Fax 413-773-9593  
DPW@greenfield-ma.gov • www.greenfield-ma.gov

**Water and Wastewater Treatment Chemicals**  
**Contract DPW 19-22**  
**Addendum #1**

**January 15, 2019**

To all Bidders:

1. Under Section C: Technical Specifications, Sub-section C.1 Sodium Hypochlorite, Paragraph 1), Line 5, change to read:

“Product shall have a pH between 12 and 13 with a specific gravity of 1.20 – 1.26.”