



City of
GREENFIELD, MASSACHUSETTS



Purchasing and Procurement

City Hall • 14 Court Square • Greenfield, MA 01301
Phone 413-772-1569
Laura.Phelps@greenfield-ma.gov

Roxann Wedegartner
Mayor

**21-07 IFB Greenfield Police Department HVAC Unit Replacement
ADDENDUM #3**

DATE: September 23, 2020

THE ORIGINAL SPECIFICATIONS DATED September 2, 2020 FOR THE ABOVE-NOTED PROJECT ARE AMENDED AS NOTED IN THE ADDENDUM #1

THIS ADDENDUM IS ISSUED FOR THE PURPOSE OF AMENDING THE REQUIREMENTS OF THE CONTRACT DOCUMENTS AND IS HEREBY MADE PART OF THE CONTRACT DRAWINGS AND SPECIFICATIONS TO THE SAME EXTENT AS THOUGH IT WERE FULLY INCORPORATED THEREIN.

Specification Clarification:

Q: Section 2.06, paragraph A of the Equipment Requirements section calls out that all units shall be provided with either 208/230 volt, three phase power. All but unit #4 of the existing equipment being replaced are served by a 208 volt, single phase service which shall remain. Unit #4 has a 460 volt, 3 phase service.

A: All new units being provided shall match the existing electrical service that is provided for the existing units they are replacing.

The City of Greenfield is extending the IFB 21-07 due date to **Monday, September 28, 2020 at 12:00pm**. With a bid opening directly to follow at the

City Hall,
2nd Floor Meeting Room
14 Court Square
Greenfield, MA 01301

**Please acknowledge this Addendum #3 on the IFB Form
END OF ADDENDUM**