



**REQUEST FOR BIDS
TOWN OF GREENFIELD
DEPARTMENT OF PLANNING & DEVELOPMENT**

Asbestos Abatement & Demolition of 29 Washington Street and
Related Work
Contract #: P&D_17-01

August 4, 2017

**REQUEST FOR BIDS
TOWN OF GREENFIELD
DEPARTMENT OF PLANNING & DEVELOPMENT**

Asbestos Abatement & Demolition of 29 Washington Street and Related Work
Contract #: P&D_17-01

Addendum #1 – August 4, 2017

Please note the following Addendum to the above Request for Bids:

Inquiry: Where will the water and sewer have to be capped?

Response: The water and sewer lines will have to be capped in the street.

Inquiry: What about the asphalt on the property?

Response: The asphalt driveway is to be saw-cut at the top where it first intersects with the parking area. All remaining asphalt (parking area and walkway) must be removed from the property.

Inquiry: Lastly, what's to be done with the fencing?

Response: The fencing is to remain; the property is to be cleaned to the fence line.

All other specifications in the original Bid document shall remain in effect.

The Town of Greenfield is an Affirmative Action/Equal Opportunity Employer.

Eric Twarog, AICP
Director of Planning & Development
Town of Greenfield
14 Court Square
Greenfield, MA 01301