

DOCUMENT 009113 - ADDENDUM

1.1 PROJECT INFORMATION

- A. Project Name: Re-Roofing Project.
- B. Project Location 70 Shelburne Rd., Greenfield, MA
- C. Owner: Town of Greenfield, 14 Court Square, Greenfield, MA
- D. Engineer: Michael Rainville, P.E.
- E. Date of Addendum: May 15, 2015.

1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum, at same time and location.

1.3 ATTACHMENTS

- A. This Addendum includes no attachments.

1.4 REVISIONS TO DIVISION 00 PROCUREMENT REQUIREMENTS AND CONTRACTING REQUIREMENTS

- A. Document: 00 01 01 Project Title Page.
  - 1. 1.1 Project Manual
    - a. Item B. Project Location: Delete “14 Court Square, Greenfield, MA” Replace with “70 Shelburne Rd., Greenfield, MA”

1.5 REVISIONS TO DIVISIONS 02 - 49 SPECIFICATION SECTIONS

- A. Specification Section 07 14 16, (not reissued).

1. Paragraph 3.2 WATERPROOFING APPLICATION

Replace Item B, line 1 as follows:

B. Unreinforced Waterproofing Applications:

1. Apply base coat (16 wet mils) and finish coat (16 wet mils) of waterproofing to obtain a dry film thickness of approximately 32 mils.

END OF DOCUMENT 00 91 13